

WHITMAN

Creating Solutions. Exceeding Expectations.

LEAD IN DRINKING WATER SAMPLING

FOR

**27 – DR. ANTONIA PANTOJA
505-517 MORRIS AVENUE
ELIZABETH, NJ 07208**

**ELIZABETH PUBLIC SCHOOLS
500 NORTH BROAD STREET
ELIZABETH, NJ 07208**

PROJECT 24-05-58T

**PERFORMED BY
WHITMAN**

September 10, 2024

LEAD IN DRINKING WATER SAMPLING
27 – DR. ANTONIA PANTOJA
505-517 MORRIS AVENUE
ELIZABETH, NJ 07208

1.0 PROJECT BACKGROUND

There are three ways that lead can contaminate drinking water in school facilities, the water source, the plumbing material, or the actual drinking water outlet fixture. Most sources of drinking water (e.g. ground and surface water) have no lead, or very low levels of lead (i.e., under 5 micrograms per liter [$\mu\text{g/l}$] or parts per billion [ppb]). Once the drinking water leaves the public water supply system or treatment plant, it comes into contact with piping and plumbing materials that may contain lead. Some lead may get into the water from the distribution system – the network of pipes that carry the water to homes, businesses, and schools in the community. Some communities have lead components in their distribution systems, such as lead joints in cast iron mains, service connections, pigtails, and goosenecks. Even though a public water supplier may deliver water that meets all Federal and State public health standards for lead, there may be lead in the drinking water because of the plumbing in the school facility. Interior plumbing, soldered joints, leaded brass fittings, and various drinking water outlets that contain lead materials are the primary contributors of lead in drinking water. It is also important to note that brass plumbing components contain lead. Since 1986, all plumbing materials must be “lead free”. Although there is an increased probability that a given plumbing component installed prior to 1986 could contain more lead than the newer components, the occurrence of lead in drinking water cannot be predicted solely based upon the age of the component or the school facility. The current law allows plumbing materials up to 0.25 percent lead to be labeled as “lead free”. However, prior to January 4, 2014, “lead free” allowed up to 8 percent lead content of the wetted surfaces of plumbing products including those labeled National Sanitation Foundation (NSF) certified. The best way to determine if a school might have elevated levels of lead in its drinking water is by testing the drinking water in that school. Testing facilitates an evaluation of the plumbing materials and helps target appropriate remedial action. It is a key step in understanding the problem, if there is one, and designing an appropriate response.

2.0 SAMPLING/SCREENING METHODOLOGY

2.1 Purpose

Lead in a water sample taken from an outlet can originate from the outlet fixture (e.g. the faucet, bubbler etc.), plumbing upstream of the outlet fixture (e.g. pipe, joints, valves, fittings etc.), or it can already be in the water that is entering the facility. Sample results are then compared to assist in determining the sources of lead contamination and the appropriate corrective measures. Prior to sampling, Whitman ensured that outlets deviating from normal usage were flushed 8-48 hours prior to sampling.

Initial first draw samples are taken from drinking water outlets and food preparation outlets (e.g., bubblers, kitchen faucets) in the facility. These samples determine the lead content of water sitting in water outlets that are used for drinking or cooking within the building(s).

2.2 NJDEP Limits

If initial first draw test results reveal lead concentrations greater than 15 µg/l (ppb) in a 250 mL sample for a given outlet, follow-up flush testing is required to determine if the lead contamination results are from the fixture or from interior plumbing.

3.0 LEAD IN DRINKING WATER SAMPLING RESULTS DISCUSSION

The summary of lead sample results is presented below. The sampling conducted complied with NJDEP protocol and all samples were submitted to Integrated Analytical Laboratories (NJDEP NELAP #14751) under a completed Chain of Custody Form.

Location	Sample ID #	Date	Time	Lead Result µg/L	NJDEP Lead Limit - µg/L	Corrective Action Taken
Room 305 Hallway Water Fountain Left	S1	8/9/2024	9:32 am	<1.00	15	
Room 305 Hallway Water Fountain Right	S2	8/9/2024	9:33 am	1.28	15	
Room 306 Hallway Water Fountain	S3	8/9/2024	9:37 am	1.02	15	
Room 312 Hallway Water Fountain	S4	8/9/2024	9:44 am	<1.00	15	
Room 246 Sink	S5	8/9/2024	9:51 am	<1.00	15	
Room 235 Hallway Water Fountain	S6	8/9/2024	9:54 am	<1.00	15	
Room 147 Water Fountain	S7	8/9/2024	10:02 am	2.01	15	
Room 147 Water Fountain Next to Sink	S8	8/9/2024	10:03 am	<1.00	15	
Room 145 Water Fountain	S9	8/9/2024	10:11 am	<1.00	15	
Room 145 Water Fountain Next to Sink	S10	8/9/2024	10:12 am	2.52	15	
Room 144 Water Fountain	S11	8/9/2024	10:16 am	<1.00	15	
Room 144 Water Fountain Next to Sink	S12	8/9/2024	10:17 am	<1.00	15	
Room 142 Water Fountain	S13	8/9/2024	10:20 am	<1.00	15	
Room 142 Water Fountain Next to Sink	S14	8/9/2024	10:21 am	<1.00	15	
Room 141 Water Fountain	S15	8/9/2024	10:24 am	<1.00	15	
Room 141 Water Fountain Next to Sink	S16	8/9/2024	10:25 am	3.05	15	
Room 139 Water Fountain	S17	8/9/2024	10:28 am	<1.00	15	
Room 139 Water Fountain Next to Sink	S18	8/9/2024	10:29 am	2.00	15	

Location	Sample ID #	Date	Time	Lead Result µg/L	NJDEP Lead Limit - µg/L	
Room 138 Water Fountain	S19	8/9/2024	10:32 am	<1.00	15	
Room 138 Water Fountain Next to Sink	S20	8/9/2024	10:33 am	4.05	15	
Room 136 Water Fountain	S21	8/9/2024	10:37 am	3.22	15	
Room 136 Water Fountain Next to Sink	S22	8/9/2024	10:38 am	66.3	15	Removed from Service
Room 150 Water Fountain Next to Sink Left	S23	8/9/2024	10:48 am	<1.00	15	
Room 150 Water Fountain Next to Sink Right	S24	8/9/2024	10:49 am	1.60	15	
Room 151 Water Fountain	S25	8/9/2024	10:53 am	<1.00	15	
Room 151 Water Fountain Next to Sink	S26	8/9/2024	10:54 am	<1.00	15	
Room 153 Water Fountain	S27	8/9/2024	10:57 am	<1.00	15	
Room 153 Water Fountain Next to Sink	S28	8/9/2024	10:58 am	<1.00	15	
Room 154 Water Fountain	S29	8/9/2024	11:03 am	1.81	15	
Room 154 Water Fountain Next to Sink	S30	8/9/2024	11:04 am	2.78	15	
Room 156 Water Fountain	S31	8/9/2024	11:07 am	<1.00	15	
Room 156 Water Fountain Next to Sink	S32	8/9/2024	11:08 am	3.24	15	
Room 161 Hallway Water Fountain	S33	8/9/2024	11:13 am	<1.00	15	
Cafetorium Water Fountain Left	S34	8/9/2024	11:18 am	1.58	15	
Cafetorium Water Fountain Right	S35	8/9/2024	11:19 am	6.45	15	
Room 165 Sink	S36	8/9/2024	11:22 am	1.36	15	
Nurse Water Fountain Left	S37	8/9/2024	11:26 am	28.4	15	Removed from Service
Nurse Water Fountain Right	S38	8/9/2024	11:27 am	12.5	15	
Nurse Sink	S39	8/9/2024	11:28 am	2.11	15	

Location	Sample ID #	Date	Time	Lead Result µg/L	NJDEP Lead Limit - µg/L	
Girl's Locker Room Water Fountain	S42	8/9/2024	11:34 am	<1.00	15	
Boy's Locker Room Water Fountain	S43	8/9/2024	11:37 am	<1.00	15	
Kitchen Prep Sink Walk-In	S44	8/9/2024	11:45 am	<1.00	15	
Kitchen Prep Sink Lockers	S45	8/9/2024	11:46 am	<1.00	15	
Kitchen Equipment 1	S46	8/9/2024	11:50 am	5.62	15	
Kitchen Equipment 2	S47	8/9/2024	11:51 am	12.9	15	
Field Blank	FB	8/9/2024	12:00 pm	<1.00	15	

4.0 CONCLUSIONS

All lead results were below the 15 µg/L New Jersey Action Level except the results listed in red.

The immediate remedial action required after an exceedance of the lead action level is to remove the water outlet from service. The District should review all the data results and plumbing profiles before deciding on remediation measures. Depending on the data and the plumbing profile some remediation measures may not be efficient at reducing the lead levels, so it is important to evaluate these.

Follow-up flush Samples are required if the Initial first-draw sample result is greater than the lead action level.

5.0 LIMITATIONS, EXCEPTIONS AND ASSUMPTIONS

Opinions and recommendations presented in this report apply to site conditions and features as they existed at the time of Whitman's site visit, and those reasonably foreseeable. They cannot necessarily apply to conditions and features of which Whitman is unaware and has not had the opportunity to evaluate.

The conclusions presented in this report are professional opinions based solely upon Whitman's visual observations of accessible areas, testing data, and current regulatory requirements. These conclusions are intended exclusively for the purpose stated herein, at the sites indicated, and for the project indicated.

No expressed or implied representation or warranty is included or intended in our reports, except that our services were performed, within the limits prescribed by our client, with the customary thoroughness and competence of our profession.

Feel free to contact me at 732-390-5858 with any questions or if further clarification is needed.

Sincerely,

A handwritten signature in blue ink, consisting of stylized, overlapping loops and a trailing horizontal line.

John Beaupre
Senior Vice President