

# Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
30-1FL-H100-W-WC-1	30	7/23/2016	< 2.0
30-1FL-H100-W-WC-2	30	7/23/2016	< 2.0
30-1FL-1-2A-W-BF	30	7/23/2016	< 2.0
30-1FL-103-S-WC	30	7/23/2016	< 2.0
30-1FL-103-W-NS	30	7/23/2016	< 2.0
30-1FL-103-N-IM	30	7/23/2016	< 1.0
30-1FL-103-N-IM	30	7/23/2016	
30-1FL-103-N-HS	30	7/23/2016	< 2.0
30-1FL-103B-N-BF	30	7/23/2016	< 2.0
30-1FL-103A-S-BF	30	7/23/2016	< 2.0
30-1FL-110E-E-TL	30	7/23/2016	< 2.0
30-1FL-110-W-WC-1	30	7/23/2016	< 2.0
30-1FL-110-W-WC-2	30	7/23/2016	< 2.0
30-1FL-111-E-HS-1	30	7/23/2016	10.1
30-1FL-111-W-HS-2	30	7/23/2016	10.1
30-1FL-111-N-HS-3	30	7/23/2016	< 2.0
30-1FL-111-E-FP-1	30	7/23/2016	< 2.0
30-1FL-111-W-FP-2	30	7/23/2016	< 2.0
30-1FL-111-W-FP-3	30	7/23/2016	< 2.0
30-1FL-111-W-FP-4	30	7/23/2016	< 2.0
30-1FL-111-E-KT	30	7/23/2016	3.6
30-1FL-111F-W-BF	30	7/23/2016	< 2.0
30-1FL-108-W-WC-1	30	7/23/2016	< 2.0
30-1FL-108-W-WC-2	30	7/23/2016	< 2.0
30-1FL-108A-E-BF	30	7/23/2016	< 2.0
30-1FL-108-S-BF-1	30	7/23/2016	< 2.0
30-1FL-108-S-BF-2	30	7/23/2016	< 2.0
30-1FL-109-W-WC-1	30	7/23/2016	< 2.0
30-1FL-109-W-WC-2	30	7/23/2016	< 2.0
30-1FL-109A-E-BF	30	7/23/2016	< 2.0
30-1FL-109-N-BF-1	30	7/23/2016	< 2.0
30-1FL-143B-W-BF	30	7/23/2016	< 2.0
30-1FL-143-E-KF	30	7/23/2016	< 2.0
30-1FL-H114-N-WC-1	30	7/23/2016	< 2.0
30-1FL-H114-N-WC-2	30	7/23/2016	< 2.0
30-1FL-114-W-BF-1	30	7/23/2016	< 2.0
30-1FL-114-W-BF-3	30	7/23/2016	< 2.0
30-1FL-113-W-BF-1	30	7/23/2016	< 2.0
30-1FL-113-W-BF-2	30	7/23/2016	< 2.0
30-1FL-141-S-BF	30	7/23/2016	< 2.0
30-1FL-116-W-CF	30	7/23/2016	< 2.0
30-1FL-116-S-WC	30	7/23/2016	< 2.0
30-1FL-116-S-BF	30	7/23/2016	< 2.0
30-1FL-139-W-CF	30	7/23/2016	< 2.0
30-1FL-139-N-WC	30	7/23/2016	< 2.0

## Water Test Results 2016

30-1FL-139-N-BF	30	7/23/2016	< 2.0
30-1FL-118-E-CF	30	7/23/2016	< 2.0
30-1FL-118-S-WC	30	7/23/2016	< 2.0
30-1FL-118-S-BF	30	7/23/2016	< 2.0
30-1FL-137-E-CF	30	7/23/2016	< 2.0
30-1FL-137-N-WC	30	7/23/2016	< 2.0
30-1FL-137-N-BF	30	7/23/2016	< 2.0
30-1FL-119-E-CF	30	7/23/2016	< 2.0
30-1FL-119-S-WC	30	7/23/2016	< 2.0
30-1FL-119-S-BF	30	7/23/2016	< 2.0
30-1FL-136-W-CF	30	7/23/2016	< 2.0
30-1FL-136-N-WC	30	7/23/2016	< 2.0
30-1FL-136-N-BF	30	7/23/2016	< 2.0
30-1FL-121-E-CF	30	7/23/2016	< 2.0
30-1FL-121-S-WC	30	7/23/2016	< 2.0
30-1FL-121-S-BF	30	7/23/2016	< 2.0
30-1FL-134-E-CF	30	7/23/2016	< 2.0
30-1FL-134-N-WC	30	7/23/2016	< 2.0
30-1FL-134-N-BF	30	7/23/2016	< 2.0
30-1FL-122-W-CF	30	7/23/2016	< 2.0
30-1FL-122-N-WC	30	7/23/2016	< 2.0
30-1FL-122-N-BF	30	7/23/2016	< 2.0
30-1FL-124-E-CF	30	7/23/2016	< 2.0
30-1FL-124-S-WC	30	7/23/2016	< 2.0
30-1FL-124-S-BF	30	7/23/2016	2.3
30-1FL-132-N-CF-1	30	7/23/2016	< 2.0
30-1FL-132-E-CF-2	30	7/23/2016	< 2.0
30-1FL-127-E-BF	30	7/23/2016	< 2.0
30-1FL-132-W-WC	30	7/23/2016	< 2.0
30-1FL-125-S-CF	30	7/23/2016	< 2.0
30-1FL-125-E-WC	30	7/23/2016	< 2.0
30-1FL-125-S-BF	30	7/23/2016	< 2.0
30-1FL-127-E-CF	30	7/23/2016	< 2.0
30-1FL-127-N-WC	30	7/23/2016	< 2.0
30-2FL-239C-S-BF-2	30	7/23/2016	< 2.0
30-2FL-239C-S-BF-1	30	7/23/2016	< 2.0
30-2FL-239B-N-BF-1	30	7/23/2016	< 2.0
30-2FL-237-E-CF	30	7/23/2016	< 2.0
30-2FL-236-W-CF	30	7/23/2016	< 2.0
30-2FL-H208-N-WC-1	30	7/23/2016	< 2.0
30-2FL-H208-N-WC-2	30	7/23/2016	< 2.0
30-2FL-208-E-BF-1	30	7/23/2016	116
30-2FL-208-E-BF-3	30	7/23/2016	< 2.0
30-2FL-207-W-BF-1	30	7/23/2016	< 2.0
30-2FL-207-W-BF-2	30	7/23/2016	< 2.0
30-2FL-235-N-CF	30	7/23/2016	3.2
30-2FL-232-E-CF	30	7/23/2016	< 2.0

## Water Test Results 2016

30-2FL-229-W-CF	30	7/23/2016	< 2.0
30-2FL-211-E-CF	30	7/23/2016	< 2.0
30-2FL-214-W-CF	30	7/23/2016	< 2.0
30-2FL-228-E-CF	30	7/23/2016	< 2.0
30-2FL-215-E-CF	30	7/23/2016	< 2.0
30-2FL-216-W-CF	30	7/23/2016	17.4
30-2FL-218-N-BF	30	7/23/2016	< 2.0
30-2FL-218-W-CF	30	7/23/2016	< 2.0
30-2FL-219-E-CF	30	7/23/2016	11.7
30-2FL-222-E-CF	30	7/23/2016	2.1
30-2FL-224-W-CF	30	7/23/2016	< 2.0
30-2FL-223-E-CF	30	7/23/2016	< 2.0
30-3FL-H328-N-WC-1	30	7/23/2016	< 2.0
30-3FL-H328-N-WC-2	30	7/23/2016	< 2.0
30-3FL-303-E-BF-1	30	7/23/2016	< 2.0
30-3FL-303-E-BF-5	30	7/23/2016	< 2.0
30-3FL-302-W-BF-1	30	7/23/2016	< 2.0
30-3FL-328-E-CF	30	7/23/2016	2.4
30-3FL-327-W-CF	30	7/23/2016	< 2.0
30-3FL-326-E-CF	30	7/23/2016	< 2.0
30-3FL-314E-S-HS	30	7/23/2016	10

### ROOM / LOCATION ID

H = Hallway (if precedes room location)

### OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

FP = Food Prep

HS = Hand Sink

IM = Ice Machine

KF= Kitchen Faucet

KT = Kettle

NS = Nurses Sink

TL = Teachers Lounge / Sink

WC = Water Cooler