

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
4-GFL-BR-S-BF	4	7/22/2016	< 2.0
4-GFL-12-W-CF	4	7/22/2016	12.1
4-GFL-KIT-W-KS-5	4	7/22/2016	2.4
4-GFL-KIT-N-HS-1	4	7/22/2016	3.9
4-GFL-KIT-N-HS-2	4	7/22/2016	< 2.0
4-GFL-KIT-N-HS-3	4	7/22/2016	< 2.0
4-GFL-KIT-S-HS-5	4	7/22/2016	2.1
4-GFL-KIT-S-KT-1	4	7/22/2016	32.7
4-GFL-KIT-S-KT-2	4	7/22/2016	8.8
4-GFL-KIT-N-KS-1	4	7/22/2016	< 2.0
4-GFL-KIT-N-KS-4	4	7/22/2016	10.4
4-GFL-KIT-S-KS-3	4	7/22/2016	< 2.0
4-GFL-KIT-N-HS-4	4	7/22/2016	3.2
4-GFL-KITB-E-BF-1	4	7/22/2016	29.4
4-GFL-KITB-E-BF-2	4	7/22/2016	5.4
4-GFL-GBR-S-BF-1	4	7/22/2016	< 2.0
4-GFL-HGBR-N-DW	4	7/22/2016	< 2.0
4-GFL-GLR-S-DW	4	7/22/2016	8.2
4-GFL-GLR-E-BF-1	4	7/22/2016	4
4-GFL-GLR-N-BF-1	4	7/22/2016	12.7
4-GFL-BLRB-S-BF-1	4	7/22/2016	< 2.0
4-GFL-BLR-W-DW	4	7/22/2016	< 2.0
4-GFL-BLR-N-BF-2	4	7/22/2016	4.5
4-GFL-BLRO-S-BF	4	7/22/2016	7.6
4-GFL-G-E-BF	4	7/22/2016	< 2.0
4-GFL-GBRW-S-BF-1	4	7/22/2016	< 2.0
4-GFL-H10-E-DW	4	7/22/2016	< 2.0
4-GFL-10-N-BF	4	7/22/2016	< 2.0
4-GFL-16-S-BF	4	7/22/2016	< 2.0
4-GFL-18-N-BF	4	7/22/2016	< 2.0
4-GFL-H17-S-DW	4	7/22/2016	< 2.0
4-GFL-13-W-CF	4	7/22/2016	< 2.0
4-GFL-BRE-S-BF-1	4	7/22/2016	< 2.0
4-1FL-NR-W-NS	4	7/22/2016	< 2.0
4-1FL-NR-W-BF	4	7/22/2016	< 2.0
4-1FL-NR-S-IM	4	7/22/2016	< 1.0
4-1FL-HNR-W-DW	4	7/22/2016	< 2.0
4-1FL-GT-05-S-BF-1	4	7/22/2016	< 2.0
4-1FL-GT-05-S-BF-3	4	7/22/2016	< 2.0
4-1FL-117-N-BF	4	7/22/2016	< 2.0
4-1FL-H119-S-DW	4	7/22/2016	< 2.0
4-1FL-103A-S-HS	4	7/22/2016	2.3
4-1FL-100A-E-BF	4	7/22/2016	< 2.0
4-1FL-102-E-CF	4	7/22/2016	< 2.0
4-1FL-H100-S-DW	4	7/22/2016	< 2.0

Water Test Results 2016

4-1FL-116-S-HS	4	7/22/2016	< 2.0
4-1FL-BT-06-N-BF-1	4	7/22/2016	< 2.0
4-1FL-H113-E-DW	4	7/22/2016	< 2.0
4-2FL-210-E-CF	4	7/22/2016	43.8
4-2FL-H212-E-DW	4	7/22/2016	< 2.0
4-2FL-GT-09-N-BF-1	4	7/22/2016	< 2.0
4-2FL-GT-10-W-BF	4	7/22/2016	< 2.0
4-2FL-H200-S-DW	4	7/22/2016	< 2.0
4-2FL-H203-S-DW	4	7/22/2016	< 2.0
4-2FL-203A-E-CF	4	7/22/2016	115
4-2FL-203-W-CF	4	7/22/2016	6740
4-2FL-FT-07-N-BF-1	4	7/22/2016	< 2.0
4-2FL-FT-07-N-BF-2	4	7/22/2016	< 2.0
4-2FL-BT-08-N-BF-1	4	7/22/2016	2.5
4-2FL-BT-08-N-BF-2	4	7/22/2016	< 2.0
4-2FL-H209-E-DW	4	7/22/2016	< 2.0
4-3FL-315-W-CF-1	4	7/22/2016	4.2
4-3FL-314-E-CF-1	4	7/22/2016	4.9
4-3FL-H317-E-DW	4	7/22/2016	2
4-3FL-GT-11-N-BF-1	4	7/22/2016	< 2.0
4-3FL-GT-11-N-BF-2	4	7/22/2016	< 2.0
4-3FL-319-S-BF	4	7/22/2016	66.3
4-3FL-300-E-CF-1	4	7/22/2016	< 2.0
4-3FL-300-S-CF-2	4	7/22/2016	14
4-3FL-320-S-DW	4	7/22/2016	79.8
4-3FL-316-S-BF	4	7/22/2016	< 2.0
4-3FL-BT-12-N-BF-1	4	7/22/2016	2
4-3FL-H308-E-DW	4	7/22/2016	< 2.0
4-3FL-BT-12-N-BF-2	4	7/22/2016	5.1

ROOM / LOCATION ID

BLRB = Boys Locker Room Bathroom

BLR = Boys Locker Room

BLRO = Boys Locker Room Office

BR = Boiler Room

BRE = Boys Room East

BT = Boys Toilet

FT = Faculty Toilet

GBR = Girls Bathroom

GBRW = Girls Bathroom West

GLR = Girls Locker Room

GT = Girls Toilet

H = Hallway (if precedes room location)

KIT = Kitchen

KITB = Kitchen Bathroom

NR = Nurses Office

Water Test Results 2016

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

HS = Hand Sink

IM = Ice Machine

KS = Kitchen Sink

KT = Kettle

NS = Nurses Sink