

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
89-LL-BBR-S-BF	89	7/13/2016	< 2
89-1-22-N-CF	89	7/13/2016	3.9
89-1-21-E-CF	89	7/13/2016	6.6
89-1-20-W-CF	89	7/13/2016	5.3
89-1-19-N-CF	89	7/13/2016	2.3
89-1-18-S-CF-2	89	7/13/2016	17
89-1-18-S-CF-1	89	7/13/2016	140
89-1-DR-W-CF	89	7/13/2016	2
89-1-H17A-N-DW	89	7/13/2016	< 2
89-1-HBR-E-BF-1	89	7/13/2016	< 2
89-1-HBR-E-BF-3	89	7/13/2016	< 2
89-1-17-N-CF	89	7/13/2016	< 2
89-1-GLR-W-BF	89	7/13/2016	< 2
89-1-16-N-CF	89	7/13/2016	< 2
89-1-BLR-E-BF-3	89	7/13/2016	< 2
89-1-GYM-S-DW	89	7/13/2016	< 2
89-1-CAF-S-WC	89	7/13/2016	< 2
89-1-KIT-1N-FP-1	89	7/13/2016	< 2
89-1-KIT-N-HS-1	89	7/13/2016	2.6
89-1-KIT-W-FP-2	89	7/13/2016	< 2
89-1-KIT-W-FP-3	89	7/13/2016	< 2
89-1-KIT-W-FP-4	89	7/13/2016	2.3
89-1-KIT-W-HS-2	89	7/13/2016	2.7
89-1-15-N-CF	89	7/13/2016	< 2
89-1-HGR-W-BF-1	89	7/13/2016	< 2
89-1-14-N-CF	89	7/13/2016	< 2
89-1-PBR-E-BF	89	7/13/2016	< 2
89-1-NOR-E-NS	89	7/13/2016	5.7
89-1-FBR-S-BF	89	7/13/2016	< 2
89-1-TR-W-TS	89	7/13/2016	< 2
89-1-12-S-CF	89	7/13/2016	< 2
89-1-11-S-CF	89	7/13/2016	< 2
89-1-10-W-DW	89	7/13/2016	7.1
89-1-10-N-BF-2	89	7/13/2016	2.4
89-1-HNUR-N-DW	89	7/13/2016	< 2
89-2-HGR-W-BF-1	89	7/13/2016	< 2
89-2-HGR-W-BF-2	89	7/13/2016	< 2
89-2-101-N-CF	89	7/13/2016	< 2
89-2-106-W-CF-1	89	7/13/2016	12
89-2-106A-S-CF	89	7/13/2016	4
89-2-106B-N-CF	89	7/13/2016	5.8
89-2-102-N-CF-1	89	7/13/2016	< 2
89-2-102-S-CF-2	89	7/13/2016	30
89-2-H102-N-DW	89	7/13/2016	480
89-2-103-N-CF-1	89	7/13/2016	< 2

Water Test Results 2016

89-2-103-S-CF-2	89	7/13/2016	12
89-2-103B-E-CF	89	7/13/2016	6.2
89-2-H103-N-DW	89	7/13/2016	280
89-2-104-N-CF-1	89	7/13/2016	< 2
89-2-104-S-CF-2	89	7/13/2016	4.7
89-2-105-S-CF	89	7/13/2016	< 2
89-2-HBR-E-BF-1	89	7/13/2016	< 2
89-2-HBR-E-BF-4	89	7/13/2016	< 2
89-M-307-N-CF	89	7/13/2016	< 2
89-M-307-W-WC	89	7/13/2016	< 2
89-M-307-S-BF	89	7/13/2016	< 2
89-M-305-S-CF	89	7/13/2016	< 2
89-M-305-W-WC	89	7/13/2016	< 2
89-M-305-N-BF	89	7/13/2016	< 2
89-M-306-S-CF	89	7/13/2016	< 2
89-M-306-E-WC	89	7/13/2016	< 2
89-M-306-N-BF	89	7/13/2016	< 2
89-M-308-N-CF	89	7/13/2016	< 2
89-M-308-E-WC	89	7/13/2016	7.5
89-M-308-S-BF	89	7/13/2016	< 2
89-M-304-N-CF	89	7/13/2016	< 2
89-M-304-E-WC	89	7/13/2016	< 2
89-M-304-S-BF	89	7/13/2016	< 2
89-M-302-S-CF	89	7/13/2016	< 2
89-M-302-E-WC	89	7/13/2016	< 2
89-M-302-N-BF	89	7/13/2016	< 2
89-M-303-N-CF	89	7/13/2016	< 2
89-M-303-W-WC	89	7/13/2016	< 2
89-M-303-S-BF	89	7/13/2016	< 2
89-M-301-S-CF	89	7/13/2016	< 2
89-M-301-W-WC	89	7/13/2016	< 2
89-M-301-N-BF	89	7/13/2016	< 2
89-M-203-E-WC	89	7/13/2016	< 2
89-M-203-N-BF	89	7/13/2016	< 2
89-M-204-E-WC	89	7/13/2016	< 2
89-M-204-S-BF	89	7/13/2016	< 2
89-M-202-W-WC	89	7/13/2016	< 2
89-M-202-S-BF	89	7/13/2016	27
89-M-201-W-WC	89	7/13/2016	< 2
89-M-201-N-BF	89	7/13/2016	< 2

ROOM / LOCATION ID

BBR = Boiler Room Bathroom

BLR = Boys Locker Room

CAF = Cafeteria

DR = Dark Room

Water Test Results 2016

FBR = Faculty Bathroom
GLR = Girls Locker Room
H = Hallway (if precedes a room number)
HBR = Hallway Boys Restroom
HGR = Hallway Girls Restroom
HNUR = Hallway at Nurses Office
KIT = Kitchen
M = Modular
NOR = Nurses Office Restroom
PBR = Principals Office Bathroom
TR = Teachers (Faculty) Room

OUTLET TYPE

BF = Bathroom Faucet
CF = Classroom Faucet
DW = Drinking Water Fountain
HS = Hand Sink
FP = Food Prep
IM = Ice Machine
NS = Nurses Sink
TS = Teachers Sink
WC = Water Cooler (Drinking Fountain)

Water Testing Results after Remediation

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
89-1-18-S-CF-1-R1	87	8/5/2016	14.1
89-1-18-S-CF-2-R1	87	8/5/2016	17.7
89-2-102-S-CF-2-R1	87	8/5/2016	8.6
89-2-H102-N-DW-R1	87	8/5/2016	< 2.0
89-2-H103-N-DW-R1	87	8/5/2016	106
89-M-202-S-BF-R1	87	8/5/2016	2.4

ROOM / LOCATION ID

H = Hallway (if precedes room location)

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain